	Date	Sample From	Sample Point	pH	Suspended Solids mg/l	Arsenic (dissolved) µ/l	Cadmium (dissolved) µ/l	Chromium (dissolved) µ/l	Copper (dissolved) µ/l	Lead (dissolved) µ/l	Mercury (dissolved) µ/l	Nickle (dissolved) µ/l	Selenium (dissolved) µ/l	Zinc (dissolved) µ/l	Total Polycyclic Aromatic Hydrocarbons	Chloride mg/l	Sulphate mg/l	Nitrate mg/l	Phosphate	Calcium mg/l	Magnesium mg/l	Sodium mg/l	Potassium mg/l	Iron µ/l	Manganese µ/l
Limit				*6-9	25mg/l	10µ/l	0.6µ/l	32µ/l	2000µ/l	14µ/l	0.07µ/l	34µ/l		10.8µ/l		250mg/l	250mg/l	50mg/l				200mg/l		200µ/l	50µ/l
	16/07/2024	Amplus	Well Monitoring Point 6	11.8	420	10.8	<0.02	<0.02	1.7	0.3	<0.05	46	3.7	2.4	3.32										
	15/08/2024	Amplus	Upstream	7.2	36	0.72	<0.02	<0.02	1.1	<0.02	<0.05	1.3	1.5	3.2	<0.16										
	15/08/2024	Amplus	Downstream	7.2	25	0.83	0.02	<0.02	5.2	<0.02	<0.05	2.4	1.6	12	<0.16										
	10/09/2024	Amplus	Upstream	8.1	83	2.76	<0.02	1.6	2.8	0.5	<0.05	2.1	2.1	2.2	<0.16										
	10/09/2024	Amplus	Downstream	7.5	18	1.11	0.02	2.1	3.3	0.2	<0.05	3.2	1.8	4.2	<0.16										
	09/09/2024	Regulation	Downstream	7.71	22											60	110	27	<0.1	51	10	68	14	280	30
	16/09/2024	Amplus	Upstream	6.9	27	0.5	<0.02	0.2	2.8	<0.2	<0.05	1.2	1.3	3.2	<0.16										
	16/09/2024	Amplus	Downstream	7.1	21	0.82	<0.02	0.7	3.1	<0.2	<0.05	1.3	1.3	9.5	<0.16										
	26/09/2024	Amplus	Downstream	7.4	<2.0	1.12	<0.02	0.9	3.2	<0.2	<0.05	1.5	1.6	8.9	<0.16										