

Report on Inspections for Application No. B/2011/0381/

Location: St. Christopher Le Vieux Beaumont,,St. Peter

Report produced on the 17/05/2019

Date	Type	Surveyor	Result	Cost
17/06/2011	Notes		Satisfactory	0.00
<b>Notes:</b> Notes: Revised/updated SER certificate J003079 received and acknowledged by fax. Details exclude balustrade design, window design and fixings.				
21/06/2011	Commencement Of Work	West	Satisfactory	0.00
<b>Notes:</b> Commencement Of Work - NOTE: all notes for this revision are on main file B/2011/0220.				
28/11/2011	Notes		Part Satisfactory	0.00
<b>Notes:</b> Notes: SER certificate J003481 for roof trusses received and acknowledged by fax. Rang Engineers and advised that cut roof section to valleys not included in design and that further details would be required (this note to be duplicated on working file B/2011/0220)				
26/01/2012	Notes		Satisfactory	0.00
<b>Notes:</b> Notes: SER certificate J003598 including cut in-fill roof (and other structural queries in relation to bracing and doubling up and bolting of joists etc) - Notes to be copied to main file B/2011/0220				